

APPROVED LIST OF AMC ELECTRICAL WORKS

S No	Name of Work	Remarks
1	Repair/Replacement of burnt/defective switch /socket /Fan regulator/bulb holder/damage sheet cover of switch boards etc.	New Fitting not be permitted. Only existing fitting will be repaired / replaced.
2	Replacement of existing fusc LED tube light fittings.	_ do _
3	Replacement of burnt wiring portion with suitable size cu conductor wiring.	Only particular portion of the wiring (which have gone burnt) will be replaced with the suitable size of cu conductor wire to make the existing system functional. (Maximum length of the replaced wiring pcr residential Qtr should not exccded 20 mtr)
4	Replacement of fresh air fans.	The fresh air fans of the toilet and kitchen will be replaced with new one after proper checking of the existing fans as repair not serve the purpose.
5	Repairing of existing defective ceiling fans/ exhaust fans.	New fitting not be permitted. Only existing fitting will be repaired / replaced.
6	Replacement of MCBs in existing distribution boards.	Burnt MCBs will be replaced as and when requirement basis.
EXTERNAL SERVICE-RELATED WORK		
7	Motor pumps sets provided for the common supply to the PS/ PC as well as sewerage system will be repaired on need basis.	The motor pump sets need to repair firstly and in casc the pump set is not repairable or repair will not serve the purposc, replacment of the pump can be done after getting approval permission of the Enginccr in Charge (EE DPHCL).
8	Repairing of control panel of the motor pump sets.	Repairing of the control panel will be done as and when requirement basis only in case the starter panel is not repairable or repair will not serve the purpose, replacement can be done after getting approval permission of the Engincer in Charge (EE DPHCL).
9	Replaccment of the existing street light fittings.	New fitting not be permitted. Only existing fitting will be repaired / replaced.
10	Repairing of underground cables for providing proper electric supply to the campuses.	New service line will not be permitted to lay and if required only particular piece (which gone defective) will be replaced. The length of the newly replaced cable picce should not be exceeded 50 Mtr per complaint.
11	Repairing of main control panel/ replacement of burnt MCCB/Main electric switch in case of breakdown etc.	This repairing will be executed only need basis in case of electric fault/breakdown in the existing system. In case the switch/panel is not repairable or repair will not serve the purpose, replacement of the MCCB/main control switch can be done after getting approval/ permission of the Engineer in Charge (EE DPHCL).
12	Period servicing of main control panels of the colony/campus (Not more than 02 times in a year).	The system which needs periodic servicing /maintenance should be serviced/maintained on due time to avoid major fault/ breakdown.
13	Painting of the rusted feeder pillars/ street light poles.	Painting will be permissible once in a year only.